

SLCBL, SLMCBL, AND SLHCBL SELF-REGULATING HEATING CABLE

LIMITED WARRANTY

BriskHeat agrees to repair or replace at the manufacturer's option any BriskHeat SLCBL, SLMCBL, and SLHCBL series self-regulating heating cable which fails to function within

ONE YEAR from the original invoice date if the failure is caused by defective workmanship or material or both.

OR

Agrees to repair or replace at the manufacturer's option any BriskHeat SLCBL, SLMCBL, and SLHCBL series self-regulating heating cable which fails to function within

FIVE YEARS from the completed installation date if all of the following conditions have been met:

1. Test of the self-regulating heating cable is performed according to the installation instructions relating to the specific application.
2. Test results and the required information requested are sent in writing to BriskHeat within 30 days of the completed self-regulating heating cable installation.
3. The self-regulating heating cable is returned to BriskHeat with proof of purchase and with a written explanation of the alleged defect(s) and/or is available for inspection by a BriskHeat representative within 30 days of the discovery of the defect(s). No cables should be returned without prior authorization from BriskHeat. For any self-regulating heating cable the consumer must prepay the shipment.

OR

Agrees to repair or replace at the manufacturer's option any BriskHeat self-regulating heating cable which fails to function within

TEN YEARS from the completed installation date if all of the above conditions have been met and: An annual report is made to BriskHeat providing megger and resistance readings.

The consumer is responsible for all costs involved in removing the self-regulating heating cable as well as all costs involved in reinstalling any repaired or replaced self-regulating heating cable. BriskHeat is not liable for any incidental and/or consequential and/or business interruption losses or damages.

Any of the following will void this warranty:

1. Failure to use appropriate BriskHeat kits
2. Failure to follow BriskHeat installation and testing instructions, cautions and warnings
3. Damage caused by abuse, misuse, alternation or mechanical abrasion
4. Damage caused by inadequate maintenance or unsafe repairs or both
5. Failure to use qualified electricians for installation
6. Failure to install cable assembly according to all applicable local electrical codes and to the National Electric Code.

BriskHeat reserves the right to inspect the installation site(s) to determine whether this limited warranty applies.

THIS LIMITED WARRANTY IS EXCLUSIVE. THERE ARE NO WARRANTIES OF MERCHANTABILITY, AND THERE ARE NO WARRANTIES WHICH EXTEND BEYOND THE DESCRIPTION ON THE FACE HEREOF.

SLCBL, SLMCBL, AND SLHCBL SELF-REGULATING HEATING CABLE

WARRANTY FORM

Installed by (Company): _____
Installation address: _____
Purchase date: _____ Purchase order number: _____
Heating cable model: _____ Heating cable batch number: _____
Heating cable rated output @ 50°F (10°C) _____ Supply voltage: _____
Circuit length: _____ ft m Size circuit breaker: _____ A
Trip level RCD/GFCI (ground fault protection): _____ ≤30mA
Min/Max Application Exposure Temperature: (Min) _____ / (Max) _____ °F °C
Insulation resistance measurements (>20 Mohm 2500V) _____
Before installation: _____ Mohm
After installation: _____ Mohm
Before insulation: _____ Mohm
Installation date: _____ Signature: _____
Installer statement: The heating cable product is installed according to BriskHeat's installation instructions and the building owner has been informed about precautions and limitations which apply to the heating cable systems
Signature/date: _____

MAINTENANCE AND ANNUAL INSPECTION

Visual Inspection

1. Visual inspection inside connection boxes for signs of overheating, corrosion, moisture, loose connections and other problems.
2. Proper electrical connection, ground, and bus wires insulated over full length.
3. Damaged or wet thermal insulation; damaged, missing, cracked lagging or weather-proofing; gaps in caulking.
4. Covered end seals, splices, and tees properly labeled on insulation cladding.
5. Control and Monitoring system checked for moisture, corrosion, set point, switch operation, capillary damage, and protection.

Comment _____

Inspection date: _____ Signature: _____

Insulation resistance test

Test A (bus to braid, 2500V): _____ Mohm

Test B (braid to pipe, 2500V): _____ Mohm

Test date/signature: _____

Power check

Circuit voltage: _____ V

Circuit amps after 10 min: _____ A

Application Exposure Temperature: _____ °F °C

Check date/signature: _____